

CERTIFICATE OF COMPLIANCE

Certificate Number 20190705-SA33319
Report Reference SA33319-20150409
Issue Date 2019-JULY-05

Issued to: CASTEL SRL
VIA PROVINCIALE 2/4
20060 PESSANO CON BORNAGO MI ITALY

**This certificate confirms that
representative samples of**

VALVES, REFRIGERANT
USL - Refrigerant check valves, Models 31 followed by 4,
followed by 4 or 5, followed by UL, W or NW, followed by 7,
9, M28, 11, 13, M42, 17, 21 or 25

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.


Standard(s) for Safety: UL 207, Standard For Safety For Refrigerant-Containing
Components and Accessories, Nonelectrical;

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

